



- PIPING MAY BE DUCTILE IRON, GALV. STEEL, OR PVC SCHEDULE 40 PER CITY STANDARD #101
- FOR STORAGE CAPACITY REQUIREMENTS REFER TO CITY OF ST. HELENA AMENDMENTS TO C.F.C. 2007
- WHEN MULTIPLE TANKS ARE UTILIZED TO ACHIEVE THE REQUIRED VOLUME OF WATER, THE CONNECTION BETWEEN THE TANKS SHALL BE BY AN APPROVED 4" DIA. WATER LINE

EMERGENCY WATER SUPPLY

ST. HELENA FIRE DEPARTMENT

1480 MAIN STREET
 ST. HELENA, CALIFORNIA 94574
 FIRE DEPT. TELEPHONE (707) 967-2880 FAX (707) 963-7057
 CITY HALL TELEPHONE (707) 967-2792 FAX (707) 963-7748

FIRE SAFE STANDARDS

NOT TO SCALE

SCALE

REVISION DATE
 MAY 15, 2009

9

DRAWING NO. 1