



One-way Access Drive:	16 feet (12 feet paved)	Access Slope	The gradient for a fire apparatus access road shall not exceed a grade of 20%.	Vegetation Clearance	Vegetation on each side of access drives and roads shall be cleared for a distance of 10'-0" from the road edge.
1-2 units					
Two-way Access Road :					
1-10 units	20 feet (16 feet paved)				
11-60 units	25 feet (21 feet paved)				
over 60 units	30 feet (26 feet paved)				
Non-residential:					

SEC 13-34, 37 ROAD & DRIVE VEGETATION CLEARANCE

ST. HELENA FIRE DEPARTMENT

1480 MAIN STREET
ST. HELENA, CALIFORNIA 94574
FIRE DEPT. TELEPHONE (707) 967-2880 FAX (707) 963-7057
CITY HALL TELEPHONE (707) 967-2792 FAX (707) 963-7748

FIRE SAFE STANDARDS

1/16" = 1'-0"

SCALE

REVISION DATE

MAY 15, 2009

2

DRAWING NO. 1